

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1070694

Product: Cylindrical fuse-links

Type: PV 10, PV 14, PV 22 aM,gG

Rating: 0,25-125 A, 500/400 V AC, 250 V DC, aM; 2-100 A, 500 V AC, 250 V DC, gG

Ordering firm: O EZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: O EZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 702745-01/01 of: 23.08.2007

A sample of the product was found to be in conformity with:
ČSN EN 60269-1:00 ed.2+A1:05, ČSN EN 60269-2:96+6:97+A1:00+A2:02, ČSN 354701-2-1:06 ed.8

The validity of the certificate is limited to: 31.8.2010

31.8.2007

Prague


Pavel Kudrna
Certification and Inspection Manager



Stamp



702745-01