

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1070838

Product: Circuit-breaker

Type: BD 250, BD 250N, BD 250S

Rating: In = 100, 160, 250 A, Un = 690 V

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 703774-01/01 of: 12.10.2007

A sample of the product was found to be in conformity with:
ČSN EN 61000-4-5:97+Z1:01+Z2:07, ČSN EN 61000-4-2:97+A1:99+Z1:01,
ČSN EN 61000-4-3:03 ed. 2+A1:03+Z1:06+Z2:07, ČSN EN 60947-1:05 ed. 3, ČSN EN 60947-2:04+Z1:04,
ČSN EN 60947-2:07 ed. 3+1:07, ČSN EN 61000-4-5:07 ed. 2, ČSN EN 61000-4-3:06 ed. 3

The validity of the certificate is limited to: 31.10.2010

19.10.2007

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



703774-01