

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1070839

Product: Circuit breakers

Type: BD 250N, BD 250S (plug-in and withdrawable type)

Rating: $U_e = 690$ V, $I_u = 250$ A, 50/60 Hz, $I_{cs} = 8$ kA

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 703776-01/01 of: 12.10.2007

A sample of the product was found to be in conformity with:
ČSN EN 60947-1:05 ed. 3, ČSN EN 60947-2:04+Z1:04, ČSN EN 60947-2:07 ed. 3+1:07

The validity of the certificate is limited to: 31.10.2010

19.10.2007

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



703776-01