

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1080416

Product: Residual current operated circuit-breakers MINIA + Auxiliary control switch

Type: OFE-...see enclosure + PS-OF-1100

Rating: In: 25, 40 A; I_{rezid.}: 30, 300 mA; U_e: AC 230 V (2p); In: 25, 40, 63 A; I_{rezid.}: 30, 300 mA;
U_e: AC 230/400 (4p) AC 230/V6 A (PS-OF-1100)

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 801277-01/01 of: 18.04.2008

A sample of the product was found to be in conformity with:
ČSN EN 61008-1:05 ed.2, ČSN EN 61008-2-1:97+A11:99, ČSN EN 60947-5-1:05 ed.2+1:05

The validity of the certificate is limited to: 30.4.2011

24.4.2008

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



801277-01

2 pole Residual current operated circuit-breakers OFE-...

type AC

OFE-25-2-030AC

OFE-25-2-300AC

OFE-40-2-30AC

OFE-40-2-300AC

4 pole Residual current operated circuit-breakers OFE- ...

type AC

OFE-25-4-030AC

OFE-25-4-300AC

OFE-40-4-030AC

OFE-40-4-300AC

OFE-63-4-030AC

OFE-63-4-300AC



Handwritten signature in blue ink.